

RELIANCE TRIAL AT THANE WEB WORLD

IN SERVER ROOM

WITHOUT AIRCO SAVER

DATE	TIME FROM/TO	kWh READING RELIANCE METER	DIFFERENCE	HOURS	kWh READING ECOPOWER METER	DIFFERENCE
15-Sep	10:10 AM	736.40	15.10	9 hrs	243.90	15.00
	7:00 PM	751.50			258.90	
16-Sep	10:05 AM	766.30	15.10	8 hrs	273.70	15.00
	6:00 PM	781.40			288.70	
17-Sep	10:10 AM	798.20	13.20	8 hrs	305.00	13.40
	12:20 AM	802.10			309.20	
	6:35 PM	811.40			318.40	

TOTAL CONSUMPTION IN 3 DAYS IN 25 HRS

43.40

PER HOUR CONSUMPTION

1.74

WITH AIRCO SAVER

19-Sep	10:35 AM	860.00	12.90	9.5 hrs	366.90	12.80
	12:00 AM	862.00			368.90	
	2:00 PM	864.80			371.70	
	4:00 PM	867.60			374.40	
	6:00 PM	869.70			376.60	
	8:00 PM	872.90			379.70	
20-Sep	10:00 AM	885.40	9.50	8 hrs	392.20	9.40
	12:00 AM	887.20			393.90	
	2:00 PM	890.50			397.20	
	4:00 PM	892.50			398.20	
	6:00 PM	894.90			401.60	
21-Sep	10:15 AM	908.90	11.20	7.5 hrs	415.50	11.20
	4:45 PM	918.60			425.20	
	5:45 PM	920.10			426.7	

TOTAL CONSUMPTION IN 3 DAYS IN 25 HRS

33.60

PER HOUR CONSUMPTION

1.34

SAVING= NO OF UNITS SAVED X 100 / UNITS CONSUMED WITHOUT AIRCO SAVER

SAVING ACHIEVED

22.58%


22/9/09
SUNIL DHAKA
TECHNICAL OFFICER
ECOPOWER PVT. LTD.

RELIANCE World
Shop No. 109-113, Ramniwas Bldg.
Naupada, Thane (W) - 400 602.

MANAGER
WEB WORLD
THANE

RELIANCE TRIAL AT OPERAHOUSE WEB WORLD

IN SERVER ROOM

WITHOUT AIRCO SAVER

<u>DATE</u>	<u>TIME FROM/TO</u>	<u>kWh READING</u>	<u>DIFFERENCE</u>
19-Aug	10:00 AM	284.6	17.90
	8:00 PM	302.50	
20-Aug	10:00 AM	317.3	15.50
	8:00 PM	332.80	
21-Aug	10:00 AM	349	16.60
	8:00 PM	365.60	

TOTAL CONSUMPTION IN 3 DAYS IN 30 HRS **50.00** 1.666667 UNITS/HRS

WITH AIRCO SAVER

<u>DATE</u>	<u>TIME FROM/TO</u>	<u>kWh READING</u>	<u>DIFFERENCE</u>
22-Aug	10:00 AM	384	13.00
	8:00 PM	397.00	
23-Aug	10:00 AM	409.9	8.90
	6:00 PM	418.80	
24-Aug	10:00 AM	438	14.30
	8:00 PM	452.30	

BEING SUNDAY WEBWORLD CLOSED
AT 6 PM ON 23 AUG


TOTAL CONSUMPTION IN 3 DAYS IN 28 HRS 36.20 1.292857 UNITS/HRS

SAVING= NO OF UNITS SAVED X 100 / UNITS CONSUMED WITHOUT AIRCO SAVER

$(1.67 - 1.29) \times 100 / 1.67$

22.40%

SAVING ACHIEVED


26-8-09
SUNIL DHARA
TECHNICAL OFFICER
ECOPOWER PVT. LTD.




MANAGER
WEB WORLD
OPERA HOUSE



RELIANCE TRIAL AT SHIVAJI PARK WEB WORLD

IN SERVER ROOM

WITHOUT AIRCO SAVER

<u>DATE</u>	<u>TIME FROM/TO</u>	<u>kWh READING</u>	<u>DIFFERENCE</u>
1-Sep	10:00 AM	554.40	4.70
	8:00 PM	559.10	
2-Sep	10:00 AM	571.90	
	8:00 PM		
3-Sep	10:00 AM	593.10	2.40
	5:00 PM	595.50	
4-Sep	10:00 AM	610.10	

WEB CLOSED AT 5 PM VIEW GANESH
VISHARGEN

TOTAL CONSUMPTION IN 3 DAYS IN 72 HRS

55.70

0.773611 UNITS/HRS

WITH AIRCO SAVER

<u>DATE</u>	<u>TIME FROM/TO</u>	<u>kWh READING</u>	<u>DIFFERENCE</u>
4-Sep	10:45 AM	610.10	3.60
	8:00 PM	613.70	
5-Sep	10:45 AM	626.40	12.10
	8:00 PM	638.50	
6-Sep	10:45 AM	642.40	1.20
	6:00 PM	643.60	
7-Sep	10:45 AM	658.30	

WEB CLOSED AT 5 PM VIEW SUNDAY

TOTAL CONSUMPTION IN 3 DAYS IN 72 HRS

48.20

0.669444 UNITS/HRS

SAVING= NO OF UNITS SAVED X 100 / UNITS CONSUMED WITHOUT AIRCO SAVER

$$(0.67 - 0.77) \times 100 / 0.77$$

13.45%

SAVING ACHIEVED


11 Sept 09

SUNIL DHAKA
TECHNICAL OFFICER
ECOPOWER PVT. LTD.


MANAGER
WEB WORLD
SHIVAJI PARK

RELIANCE WORLD
GROUND FLOOR, ATHAVA BLDG.,
KELUSKAR ROAD,
OPP. SHIV SENA BHAVAN,
DADAR (WEST), MUMBAI-400 028.